

Technical Memorandum

DATE: March 14, 2017 PROJECT: 15-2-112

TO: Gordon Stankowski & Paul Fuchslin
North Rural Vacaville Water District (Solano Irrigation District)

FROM: John Fawcett & Gregory Garrison

SUBJECT: **WELL 2 OPTIONS TO REDUCE ARSENIC
NORTH RURAL VACAVILLE WATER DISTRICT**

INTRODUCTION

Well 2 was constructed in 2001. Since the well's construction, samples from Well 2 have had arsenic concentrations ranging from about 5 to 21 parts per billion (ppb). In 2001, the Well 2 water quality samples met the Department of Drinking Water (DDW) maximum contaminant level (MCL) standard of 50 ppb for arsenic; in 2008 the arsenic MCL standard was lowered to 10 ppb. The Well 2 water quality exceeds the current arsenic MCL standard. The current Rural North Vacaville Water District (RNVWD) water supply permit issued by the DDW allows the well to be used as a domestic well supply on an emergency standby basis.

RNVWD desires to improve water supply reliability by reducing arsenic levels in Well 2 and retained Lohdorff and Scalmanini Consulting Engineers (LSCE) for assessing possible the following options that could lower arsenic levels in Well 2 water:

1. Blending Well 2 water with Well 1 to achieve an arsenic level that meets the 10 ppb standard;
2. Construction of a new, low arsenic well to replace Well 2;
3. Modifications to the existing Well 2 structure to limit arsenic entry into the well casing;
4. Groundwater treatment to remove arsenic.

This report includes a review and analysis of the available well information; water quality data including the results of recent groundwater sampling conducted in October 2016, December 2016, and January 2017; and a summary of findings and recommendations associated with each of the above options that may reduce the concentration of arsenic in water produced from Well 2.

DESCRIPTION OF RNVWD WATER SYSTEM

Per the DDW 2013 Sanitary Survey Report, RNVWD is a community water system that serves a population of approximately 900 through 372 metered service connections. The water supply consists of two wells drilled to a depth of 1,400 feet (ft), each having a capacity of 450 gallons per minute. Well 2 has been placed on emergency standby since the average arsenic concentration has consistently exceeded the 10 ppb MCL. Well 1 remains the only source for reliable production, with arsenic levels consistently holding at 6 ppb or less.

RNVWD operates and maintains two water supply wells, discussed previously, along with one booster pump station (two booster pumps each that pump 250 gallons per minute), two 300,000-gallon storage tanks, two chlorine injection systems, and a Supervisory Control and Data Acquisition (SCADA) System. RNVWD maintains a water distribution infrastructure that includes 43 miles of PVC and cast iron pipelines that deliver water over variable terrain to different pressure zones and 67 fire hydrants. All potable water distributed by RNVWD contains chlorine residual for disinfection purposes.

The DDW issued water supply permit No. 02-04-00P-4810013 on June 16, 2000, classifying RNVWD as a small community water system based upon both population and number of service connections.

WATER SUPPLY

RNVWD has one active groundwater source (Well 1) and one emergency standby groundwater source (Well 2). Well 1 and Well 2 are located in North Vacaville at the end of Buena Vista Lane and are approximately 1,000 feet apart. Hydrogeologically, the wells are in the Solano subbasin of the Sacramento Valley Groundwater Basin (DWR Basin No. 5-21.66). The well construction details for both wells are summarized in **Table 1** (DDW/CDPH, 2013 Sanitary Survey Report). Well profiles for both Well 1 and Well 2 are included in **Figure 1**.

Table 1: Well Construction Summary Wells 1 & 2

Source (PS Code)	Status	Capacity (gpm)	Well Depth (ft.)	Drilling Date	Pump
Well 1 (4810013-001)	Active	450	1391	10/11/2001	75 hp Vert. Turbine
Well 2 (4810013-002)	Standby	450	1284	10/29/2001	75 hp Vert. Turbine

Source	Casing Material	Casing Diameter	Annular Seal Depth (ft.)	Annular Seal Material
Well 1	Steel	16.625"	902	Cement Grout
Well 2	Steel	16.625"	901	Cement Grout
Source	Openings Sealed	Casing Vent	Air Relief Valve	Screen Intervals (feet below ground surface elevation)
Well 1	Yes	Yes	Yes	1017/1047; 1169/1189; 1245/1261; 1271/1291; 1351/1361
Well 2	Yes	Yes	Yes	1071/1099; 1210/1240

The original design capacity of each well was 500 gallons per minute (gpm). During development pumping in 2001, each well was fully developed at flow rates of approximately 1,400 gpm. Well and aquifer tests were performed on each well. Constant-rate tests for both wells were conducted at the design capacity of 500 gpm. Well 1 was continuously pumped for 16 hours and Well 2 was continuously pumped for 24 hours. The specific capacity and aquifer transmissivity is summarized in **Table 2**.

Table 2: Well Specific Capacity & Aquifer Transmissivity

	Specific Capacity (gpm/ft)	Aquifer Transmissivity (gpd/ft)
Well 1	9	18,000
Well 2	5	12,750

Water Demand & Adequacy of Supply

DDW requires RNVWD's water supply to meet the Maximum Day Demand (MDD). MDD is defined as the largest volume of water delivered to the system in a single day expressed in gallons per day. For purposes of this report, LSCE assumes that the MMD demand is 0.494 million gallons (MG) or 350 gpm, as reported in the CDPH 2013 Sanitary Survey Report, is still applicable (i.e. LSCE's scope for this project did not include a water demand update or an assessment of the current MDD).

The capacity of active Well 1 is 0.648 million gallons per day (MGD), or 450 gpm. Well 2 is an additional emergency source that is approximately equal to Well 1. RNVWD has an additional 0.600 MG of water storage capacity in their tanks. Per the DDW, RNVWD has sufficient water available to meet its MDD and comply with the CDPH requirements for reliable source, storage, emergency capacity, and fire suppression (DDW/CDPH, 2013 Sanitary Survey Report).

Although RNVWD is pursuing options to reduce arsenic in groundwater pumped from Well 2, RNVWD's desire to add arsenic treatment is not strictly regulatory driven; meaning RNVWD is pursuing the treatment option for Well 2 not because there is a regulatory directive, but because of a desire to improve source water reliability and redundancy.

As discussed above, the DDW classifies Well 2 as an emergency standby groundwater source. Title 22 restrictions on standby wells include:

- Well 2 can only be used for short term emergencies of 5 consecutive days or less and less than 15 calendar days a year;
- Within 3 days after use of Well 2 as standby source, RNVWD must notify the DDW; and
- Well 2 must be monitored a minimum of once every compliance cycle.

Compliance with DDW Well 2 standby regulations apply to the situation of Well 1 being off-line for 5 consecutive days or less. Should Well 1 fail due to a well pump or motor problem, the problem could be addressed within 5 days provided spare parts and a well pump contractor is available. However, problems associated with the well itself could be more time consuming to address. For example, should the well experience a decline in well yield, an investigation and implementation of a well rehabilitation plan could be needed, and this work could require more than 5 days to completed. For certain, well structure damage caused by corrosion, settlement, or earthquakes would take longer than 5 days to address and having Well 2 available, and in “active” status instead of “standby”, would improve RNVWD’s system reliability.

Water Quality

The DDW requires that the Well 1 and Well 2 groundwater meet Title 22 water quality requirements. Historically, both wells met maximum contaminant level (MCL) standards except for the concentration of arsenic levels in Well 2. First sampled in 2001, arsenic concentrations in Well 1 have ranged from 4 to 7.5 ppb. Whereas, arsenic concentrations in Well 2 have been reported to range from about 5 to 23 ppb, but more generally levels range from 15 to 20 ppb, exceeding the 10 ppb MCL standard. Well 2 arsenic levels increase with pumping duration and pumping flow rate as described further below.

Arsenic Water Quality

Arsenic levels in Well 1 and Well 2 were investigated on many occasions since originally tested in 2001 and can be summarized as follows:

- October 2016, December 2016, and January 2017: RVNWD collected samples from Well 2 on three occasions and arsenic levels were 4.2, 12, and 6.9 ppb, respectively. The water quality laboratory reports prepared by BSK Laboratories are included in **Appendix A**. The variation in water quality may relate with the flow rate and duration of pumping. As discussed below, concentrations of arsenic that exceed the 10 ppb standard may be representative of the water quality associated with longer term pumping, whereas the lower arsenic levels may be representative of samples obtained from well casing storage and less representative of the hydrogeologic formation water quality. Well 1 was sampled on October 2016 only and the arsenic level was measured at 6.2 ppb. The December sample was obtained following pumping for 5 minutes. The December and January samples were obtained following pumping at a rate of 400 gpm for 12 minutes.
- 2015: RVNWD collected and analyzed several samples in March (3/19 through 3/24) from Well 2. A total of 14 samples were obtained. Arsenic levels ranged from 11 to 15 ppb. One of the 14 samples was also tested for manganese and hexavalent chromium and the concentrations were reported as non-detect. No information was available regarding well pumping rate.
- 2005: LSCE conducted Well 1 and Well 2 time series sampling in August 2005 as follows:
Well 1: Time-series samples with the well running were obtained on August 8th at 9:00 AM, 10:00 AM, 12:00 PM, and 4:00 PM. All the analyzed samples had arsenic concentrations of

about 5 ppb. The arsenic concentration did not vary with time, and did not exceed the MCL.

Well 2: Was not running when LSCE arrived at the site, so time-series samples were obtained from start-up. Samples were collected on August 6 at 5 minutes and at 1, 2, 4, and 8 hours into the pumping cycle. The analyzed samples had arsenic concentrations that ranged from 6.7 to 23.1 ppb. The samples that were obtained at 5 minutes into the pumping cycle had arsenic concentrations below MCL, however, these samples may represent water stored in the well casing and not the formation water. Similarly, the two samples that were at approximately 5 ppb in January 2004 were likely obtained from casing storage and not representative of a change in formation water quality. The arsenic concentration in subsequent time-series samples did not vary with time and ranged from 17.2 to 23.1 ppb.

- 2001: Well 1 water quality met the 10 ppb MCL level and samples from Well 2 had arsenic concentrations ranging from 15 to 21 ppb during LSCE test pumping discussed above. During the 24 hour aquifer test, the arsenic concentration in Well 2 was 16 ppb. Water quality samples were collected during the constant-rate tests conducted at each well.

Water Quality Parameters that Affect Arsenic Treatment

Water samples collected from Well 2 in October 2016, December 2016, and January 2017 were also analyzed for metals and general chemistry parameters by BSK Laboratories. The water quality data is presented in **Appendix A**. **Appendix A** also includes similar analytical testing conducted by Cal Aqua Lab in May 2014.

LSCE provided the BSK and Cal Aqua **Appendix A** analytical data to several arsenic treatment companies as part of the solicitation of technical feasibility and cost information needed to assess Well 2 treatment options. Several parameters tested, including silica, phosphorus, and vanadium, present adverse impacts to arsenic treatment as discussed further in the water treatment option assessment, below.

ASSESSMENT OF WELL 2 ARSENIC REDUCING OPTIONS

As discussed above, Well 2 has been placed on emergency standby as the average arsenic concentration has consistently exceeded the 10 ppb MCL standard. Well 1 remains the only source for reliable production, with arsenic levels consistently measured at 6 ppb or less.

The RNVWD desires to upgrade Well 2 for domestic supply and is interested in options to reduce the concentration of arsenic in the water to below DDW standards. RNVWD Well 2 options for reducing the arsenic concentration include the following:

- Option 1: Blending Well 2 with Well 1;
- Option 2: Construction of a new, low arsenic well to replace Well 2;
- Option 3: Well structure modifications to preclude entry of arsenic into to the well casing;
- Option 4: Well head treatment.

Option 1: Blending Well 2 with Well 1

The first arsenic-reducing option examined was the feasibility of using an alternate water source for blending purposes. In this case, RNVWD could combine (blend) water pumped from Well 1 (arsenic <5 µg/L) with Well 2 (arsenic ranging from about 5 to 23.1 ppb) by pumping both wells into the existing hydropneumatic tank located at the Well 1 site and then into the RNVWD distribution system where the blended supply is served to customers.

The blending concept with Well 1 and Well 2 is not feasible because if Well 1 is out-of-service for any reason, Well 2 would not be able to produce water that meets the arsenic MCL standard of 10 ppb. For these reasons, Option 1 is eliminated from further consideration or analyses.

Option 2: Construct New Production Well

Conceptually, Well 2 could be replaced with a new production well that is located, designed, and installed to have arsenic levels below the 10 ppb MCL. As describe earlier in Section 3 above, Well 1 and Well 2 are completed in the same Solano subbasin (Tehama formation) and are located only 1,000 feet apart. To best ensure that the new production well has the same water production capability and produces water with arsenic levels lower than the 10 ppb, the well should be located as close as possible to Well 1.

As discussed in Section 4, the MDD can be met with a single well. Therefore, it is not required that Well 1 and the new well operate at the same time, thus there would not be a concern with mutual pumping interference.

The main down-side for the new well option is the cost. **Table 3** includes a cost summary for a new well replacement project (\$1,350,000). The well cost component (\$750,000) is based upon the Well 1 design, well development, testing, and LSCE's experience with recent wells constructed and equipped with steel well casing, stainless steel blank casing, stainless steel louvered well screen(s), a sounding pipe, and a gravel fill pipe. The well pump station upgrade cost component associated with this option (\$250,000) includes a new well pump and motor, pump pedestal, piping and controls, chemical disinfection system upgrades, and electrical improvements. **Table 3** includes a summary of the contingency costs that cover unanticipated construction costs, design and planning, construction management, and program administration.

Another con of constructing a new well, besides cost, is that there is still some risk that the water quality could still exceed the 10 ppb arsenic standard. A pro of the new well option is that the long-term cost for operating the well would be less than the well treatment to remove arsenic discussed below. In addition, having a new well enhances long term system reliability, i.e. both Well 1 and No. 2 are already 16 years old (the life expectancy of a new well is expected to be about 40 to 50 years).

Table 3: Planning Level Cost Estimate for New Well & Pump Station

Item	Planning Level Cost Estimate
Well Construction	\$750,000
Well Pump and Station Piping Construction	\$250,000
Capital Cost Subtotal:	\$1,000,000
Construction Contingency (10%)	\$100,000
Design & Planning (10%)	\$100,000
Construction Management (10%)	\$100,000
Project Administration/Management (5%)	\$50,000
Total:	\$1,350,000

Notes:

1) Construction (10% contingency allowance): Costs are representative of the construction under normal construction conditions and schedules. Consequently, it is appropriate to allow for estimating and construction uncertainties unavoidably associated with conceptual planning of projects. Factors such as unexpected construction conditions, the need for unforeseen mechanical items, variations, and final quantities are only a few of the items that can increase project costs.

2) Design and Planning (10% contingency allowance): Design and planning services associated with new facilities include preliminary investigations and reports, right-of-way acquisition, foundation explorations, preparation of drawings and specifications for construction, surveying and staking, sampling of testing material, and start-up services. The cost of these items may vary, for example, the new well cost will be on or close to the Well 1 site, reducing the need for a design/planning contingency.

3) Construction Management (10% contingency allowance): Construction management covers contract management and inspection during construction. For this study, it is assumed that construction management costs will equal 10 percent of the base construction cost.

4) Program Administration (5% contingency allowance): Program administration covers items such as legal fees, environmental/CEQA compliance requirements, financing expenses, and interest during construction. The cost of these items may vary, but for this study, it is assumed that program administration costs will equal 5 percent of the base construction cost.

Option 3: Well 2 Structure Modifications to Limit Arsenic Levels

As indicated in **Table 1** and **Figure 1**, Well 2 is screened across two depth intervals. The uppermost screen was constructed from 1,071 to 1,099 feet below ground surface (bgs), and the lower screen was constructed from 1,210 to 1,240 feet bgs. Conceptually, it is possible, if information was available on which screened section is the source of arsenic that is entering the well, to physically modify the well to limit the entry of arsenic. Example well modifications include installation of a well liner/sleeving, packer installation, swaging, and well plug-backing. It should be recognized that well modifications that limit the

entry of water into the well casing will result in an increase of pumping water level and a resulting increase in power costs.

LSCE conducted packer testing in 2001 to evaluate the technical feasibility of making Well 2 structural modifications to limit entry of arsenic; i.e. packer tests were conducted to define the vertical distribution of water quality (arsenic) and hydraulic conductivity (pathways for water and contaminant movement). A packer test consists of isolating sections of a well using inflatable packers (bladders) so that water-quality samples can be collected and aquifer tests can be conducted.

The results of LSCE packer testing are summarized in **Table 4**. The packer tests results show that arsenic is entering the well through both well screen intervals at concentrations that exceed the MCL limit (see **Table 4**). Therefore, the packer test results suggest that Option 3 of implementing Well 2 structural modifications to limit entry of arsenic by restricting flow through either well screen is technically unfeasible and therefore Option 3 is dropped from further consideration.

Table 4: Well 2 Packer Test Results

Screened Area	Upper Screened Interval 1071 – 1099' bgs			Lower Screened Interval 1210 – 1240' bgs		
Date	11/07/2001			11/08/2001		
Test Duration	8 Hours			8 Hours		
Static Water Level	126.9 feet			129.8 feet		
Average Discharge Rate	111 gpm			162 gpm		
Drawdown	78.9 feet			37.6 feet		
Specific Capacity (24 Hours)	1.3 gpm/ft.			4.2 gpm/ft.		
Testing Interval	As	Mn	Fe	As	Mn	Fe
2-Hour	0.016	ND	0.250	0.016	0.069	0.250
4-Hour	0.015	ND	0.220	0.018	0.071	0.300
6-Hour	0.016	ND	0.190	0.018	0.070	0.280
8-Hour, Filtered	0.015	ND	0.130	0.019	0.069	0.250
8-Hour	0.017	0.015	0.250	0.016	0.066	0.250

Notes:

- 1) All units ppm.
- 2) Arsenic (As) MCL= 0.010 ppm; Manganese (Mn) MCL= 0.050 ppm, Iron (Fe)= 0.300 ppm.

Option 4: Water Treatment Options

As discussed above, for purposes of this report, the proposed Well 2 water treatment system must be capable of treating 350 gpm (MDD), and enough arsenic must be removed to meet the 10 ppb MCL water quality standard for arsenic.

A wide range of technologies has been developed for the removal of high concentrations of arsenic from drinking water. The most common arsenic removal technologies use oxidation, coagulation, precipitation adsorption, ion exchange, and membrane techniques.

There are several Well 2 treatment option available for removing arsenic. Most arsenic removal technologies will fall into three treatment categories and treatment subgroups:

- Adsorption media processes:
 - Activated alumina
 - Granular ferric hydroxide
 - Ion Exchange
- Chemical Precipitation Processes:
 - Iron and manganese removal with co-precipitation of arsenic
- Membrane processes: processes:
 - Reverse osmosis
 - Nanofiltration
 - Electrodialysis (ED) and Electrodialysis Reversal (EDR)

Of the various treatment technologies listed above, ion exchange and all membrane processes (reverse osmosis, nanofiltration, and electrodialysis and electrodialysis reversal), although capable of removing arsenic, were ruled out because of high process operation and maintenance costs and because of the technical challenges and costs for managing residuals generated as part of the treatment process. Both the adsorptive media process and the chemical precipitation process were retained for further consideration and are discussed further below.

Adsorptive Media Versus Chemical Precipitation

This section presents a brief discussion of various adsorptive media and the chemical precipitation process technologies and includes a comparison based upon four main criteria:

1. Water quality characteristics (including pH levels and initial concentrations of Fe, As(III), As(V), and other ions present in the water that can interfere with treatment);
2. Ease of implementation with current system (Well 2 treatment will occur at the Well 1 site);
3. Residual management (all treatment options include the generation of a waste product that must be managed); and
4. Cost.

Adsorption Media Processes

Arsenic can be removed by passing untreated water through adsorptive granular media contained in a pressure vessel. As the water passes through the media, the negatively charged arsenic ions are adsorbed

onto the surfaces of the positively charged media particles. There are several adsorption media available: activated alumina (AA), titanium based media, zirconium based media, and iron based sorbents. The most common media include modified activated alumina and iron-based materials.

RNVWD has pursued adsorption media treatment and has contacted many vendors over the past three years that offer skid-type well head treatment units. LSCE re-established contact with the following adsorptive media vendors:

- Denova/Severn Trent Services (media type: Sorb 33/E33)
- AdEdge Technologies (media type: granular iron media/E33)
- Applied Process Equipment (APE Water) (media type: Purolite-Bayoxide E33 replacement, Isolux – zirconium base; and EP Minerals – lanthanum based).

Generally, adsorptive type well head treatment units are relatively low-cost and simple to operate. However, competing ions present in Well 2 groundwater will cause the media to be inefficient in terms of adsorption of arsenic, and therefore the operational cost to replace media can be very high depending upon the volume of water to be treated. As discussed in Section 5 above, recent analytical testing of Wells 1 and 2 for both metals and general chemistry indicate that Well 2 has elevated levels of silica, phosphorus, and vanadium. These ions compete for adsorption sites and negatively impact arsenic removal performance using adsorptive media. The vendors all reported (based upon media model runs) that the adsorptive media is not well suited for treatment of Well 2 because of the silica, orthophosphate, and vanadium constituents that are consuming the media. The only way that the adsorptive media process can compete with the chemical precipitation process in terms of operational cost is if the volume of Well 2 water is minimized (i.e. treating less volume means the adsorptive media will last longer before being spent and having to be replaced with new media).

Conversation with the RNVWD general manager indicated a reasonable assumption may be to assume that Well 1 could be off-line for a two-month period, and therefore Well 2 treatment would be needed for this two-month down-time. LSCE evaluated recent water use records and determined the maximum volume to be treated for a two-month period occurs during the summer months. As illustrated, in **Figure 2**, the maximum two-month volume of water to be treated is about 12 MG. Therefore, for operational cost purposes, it is assumed that the Well 2 treatment system will operate for a two-month period and treat 12 MG.

The adsorptive media systems require backwash to remove particulates and redistribute the bed material. The liquid residuals from the filter backwashing step contain low concentrations of arsenic that may have to be managed. Spent media will also need to be tested/disposed of as either a solid or hazardous waste. In some cases, spent media can be regenerated off-site.

Chemical Precipitation Processes

Oxidation/filtration is a precipitative process used to remove arsenic. In oxidation/filtration processes, groundwater pumped from Well 2 is passed through a vessel of manganese-oxide (MnOx) media which

adsorbs and catalyzes the oxidation of the iron and manganese. The filtering capacity of the granular manganese-oxide media then retains the precipitated iron, manganese, and arsenic until it is backwashed out of the vessel. Backwashing creates wastewater and sludge that must be properly disposed as discussed below. Arsenic appears to be removed primarily by the iron precipitates as opposed to those of manganese. Because the Well 2 groundwater has low levels of influent iron (less than 1.5 mg/L or less than 20:1 ratio with arsenic) adding ferric chloride prior to oxidation will likely be required. Recent water quality data is included in **Appendix A**.

Manganese-oxide (MnOx) media, which include manganese greensand and pyrolusite, are commonly used in oxidation/filtration processes because of their unique adsorptive and catalytic capabilities. Greensand is manufactured by coating glauconite with manganese dioxide, while pyrolusite is a naturally mined ore composed of solid manganese dioxide. Greensand media has been shown to be capable of removing up to 80% of arsenic by oxidation and adsorption. It is generally recommended that greensand be preceded by a 12-inch anthracite cap to filter any precipitated iron particulates before the green sand.

For greensand to retain its adsorption and catalytic oxidation capabilities for iron and manganese removal, the media must be regenerated, typically using chlorine. The sodium hypochlorite oxidant is added ahead of the filter where it provides continuous oxidation of the contaminants as well as regeneration of the MnOx media. Arsenic adsorbs to the iron floc formed in this chemical oxidation step and is physically filtered from solution by the greensand. Any arsenic that is not oxidized is adsorbed onto the MnO₂ surface of the greensand particles.

RNVWD has considered Well 2 oxidation/filtration treatment processes and has contacted many vendors over the past three years that offer skid-type well head treatment units. In addition, LSCE contacted two additional vendors. Vendors that provided input on the Well 2 project include:

- Tonka Water/Hopkins Technical Products (media type: Tonka Water IMAR™ filter media)
- AdEdge Technologies (media type: APU26 Coagulation/Filtration)
- Hungerford & Terry/Ward Technical Products (media type: Greensand Plus Filtration System)
- ATEC Systems (media type: AS 741 M pyrolusite)
- Loprest Water Treatment (media type: Greensand or Filter Sand/Anthracite)

Comparison Summary - Adsorptive Media vs Chemical Precipitation

A comparison the adsorptive media and chemical precipitation options are presented in **Table 5**. Both adsorptive media and chemical precipitation processes are effective in removing arsenic to levels below the 10 ppb MCL standard. Adsorptive media units can achieve a relatively lower concentration of arsenic and this in turn may allow for blending of Well 2 (i.e. the incoming flow from Well 2 can be split prior to treatment resulting in a blend of Well 2 treated water with Well 2 untreated water, effectively reducing the filter unit size and cost). Also, should the DDW lower the arsenic standard in the future, the adsorptive media option is preferred as it can achieve a finished water quality that has a much lower concentration of arsenic than the current MCL.

As discussed above, recent RNVWD testing indicates that Well 2 has elevated levels of silica, phosphorus, and vanadium. These ions compete for adsorption sites and negatively impact arsenic removal performance using adsorptive media. The adsorptive media is not well suited for treatment of Well 2 because of the silica, orthophosphate, and vanadium constituents that would consume the media. Because of the unique Well 2 water quality and the presence of competing ions for adsorption, the only way that the adsorptive media process can compete with the chemical precipitation process would be if the total volume of water to be treated is relatively low (i.e. Well 2 well head treatment will only operate if Well 1 is brought off-line for maintenance).

Table 5 indicates that the chemical feed requirements are similar for adsorptive media and chemical precipitation process, except that ferric chloride addition is required for chemical precipitation.

The ease of operation for an adsorptive media is less because of the need for additional chemical treatment and because of the operational needs associated with more sludge production in the case of chemical precipitation. In addition, the level of operator training and expertise required to operate an adsorptive media is less than the coagulation/filtration treatment process.

In terms of residual management, the adsorption process will generate spent media that retains the arsenic and therefore must be tested for hazardous waste and disposed at approved disposal site. However, the adsorption process generates a relatively low volume of filter media backwash water/sludge that must be tested and disposed. It is likely that the backwash solids will be non-hazardous because the media will retain the arsenic. With the chemical precipitation, the volume of backwash water will be significantly more due to the addition of ferric chloride, and the arsenic will be present in the filter backwash water making disposal more of a potential problem because the backwash solids could require testing and judged to be hazardous, which increases disposal costs.

Finally, as shown on **Table 5**, the capital, construction cost, and probably the annual operation and maintenance costs, will be lower for the adsorptive media option. Again, this assumes that the total volume treated is 12 MG (the volume associated with having to treat for a two-months period). The annual operating cost will depend upon the residuals generated by the treatment process and the cost for residual permitting, transportation, and disposal.

Option 4 capital costs for adsorptive media treatment (\$750,000) is estimated to be lower than chemical precipitation treatment (\$950,000). The operational costs for an adsorptive media is also less than the coagulation/filtration treatment process because of the need for additional chemical treatment and because of the operational needs associated with more sludge production in the case of chemical precipitation. Both adsorptive media chemical precipitation units will have media filters that must be conditioned and have chemical feed systems that must be operated more-or-less monthly to ensure an ability to effectively remove arsenic when called upon to operate (when Well 1 fails to operate and must be brought off-line). Although well head treatment may be used infrequently, the operating costs and ease for the RNVWD operators to carry out routine operations to ensure the Well 2 treatment system is

available at a moment's notice, is expected to be lower for adsorptive media units than for chemical precipitation units. Pilot testing (discussed below) will be used to verify cost assumptions.

Table 5: Comparison of Treatment Technologies

Treatment Process	Adsorption Media	Coagulation/Filtration
Arsenic Species	As (V) > As (III)	As (V) > As (III)
Competing Ions in Well 2 (silica, phosphorus, and vanadium)	Large Impact on treatment efficiency	Moderate Impact
Chemical Feed	<ul style="list-style-type: none"> • Acid to depress pH • NaOH base to raise pH for corrosion • Coagulant for solids 	<ul style="list-style-type: none"> • Pre-oxidation • Acid to depress pH • NaOH base to raise pH for corrosion • Requires ferric chloride addition • Coagulant for solids
Ease of Operation	Relatively simple	Relatively more complex
Residual Management	<ul style="list-style-type: none"> • Spent media is tested for hazardous waste and disposed at approved disposal site • Generates relatively low volume of filter media backwash water/sludge that must be tested and disposed—likely non-hazardous, but could involve dewatering 	<ul style="list-style-type: none"> • Generates backwash water and more sludge than adsorption, it also contains arsenic and must be tested • POTW may not accept • Dewatering backwash sludge may be required, may be tested, and judged to be hazardous
Vendors Capital Cost	\$300,000	\$400,000
Construction Capital Cost	\$250,000	\$300,000
Total Capital Cost	<p>\$550,000 (not including sludge dewatering if required)</p> <p>\$750,000 with contingency costs that cover unanticipated construction costs, plus design and planning, construction management and program administration (see Table 3)</p>	<p>\$700,000 (not including sludge dewatering if required)</p> <p>\$950,000 with contingency costs that cover unanticipated construction costs, plus design and planning, construction management and program administration (see Table 3)</p>
Annual O&M (assumes total volume treated is 12 MG- the volume associated with max two-month flow)	<ul style="list-style-type: none"> • Depends upon media replacement rate to be determined by Pilot Testing • Cost will be lower than coagulation/filtration option 	<ul style="list-style-type: none"> • Depends upon sludge production rate and testing determined by Pilot Testing • Cost will be higher than adsorption media option

Conclusions Regarding Options 1 through 4

Option 1: Blending Well 2 water with Well 1 to achieve an arsenic level that meets the 10 ppb standard is not feasible because if Well 1 is out-of-service for any reason, Well 2 would not be able to produce water that meets the arsenic MCL of 10 ppb.

Option 2: Construction of a new, low arsenic well to replace Well 2 is technically feasible. Well 1 produces water with arsenic levels about half the 10 ppb MCL. Therefore, this option would involve constructing a new well located as close as possible to Well 1. A new well replacement project is estimated to cost \$1,350,000. Unfortunately, there would still be some risk that the water quality could still exceed the 10 ppb arsenic standard.

Option 3: LSCE conducted packer testing which suggests that modifications to the existing Well 2 structure to limit arsenic entry into the well casing is technically unfeasible.

Option 4: Well 2 treatment is technically feasible and can more reliably meet the 10 ppb arsenic standard when compared to all options. In addition, the capital cost for Option 4 is less than the only other technically feasible option (Option 2). The annual operating cost for Option 4 is more than Option 2, but the lower operating cost for Option 2 is judged to not be significant enough to off-set the risk of not meeting the 10 ppb arsenic standard.

If RNVWD will pursue Well 2 treatment, the next steps in the process includes pilot testing and preparation of an engineering feasibility report as described further below.

Pilot testing

Well 2 pilot testing is required to determine the optimum configurations and operating conditions for meeting the drinking water standard for arsenic. The pilot testing will also provide information on the quantity of residuals generated by treatment and whether the residuals are hazardous or nonhazardous. In summary, the purpose of performing a Well 2 pilot test are as follows:

- 1) To determine whether and under what operating conditions the technology can remove arsenic to meet the 10 ppb MCL requirement;
- 2) To determine residuals characteristics when the technology is operated to achieve sufficient arsenic removal;
- 3) To determine optimum operating parameters to remove sufficient arsenic while maintaining non-hazardous residual generation; and,
- 4) The pilot test is needed to establish a guaranteed treatment removal effectiveness (contractual commitment between the vendor and RNVWD).

Based on the analyses above, the adsorptive media process is preferred over the chemical precipitation process. However, because of competing ions present in Well 2 groundwater, and because of the

uncertainty regarding residual management options and costs, LSCE recommends pilot testing both the adsorptive media and the chemical precipitation processes. Pilot testing costs about \$10,000 to \$20,000 per test. LSCE also recommends selecting a pilot testing company from the list of adsorptive media and chemical precipitation process vendors discussed above.

The Well 2 pilot testing will require that Well 2 be pumped to waste at the design flow of 350-gpm. Since the duration of the pilot testing could extend over a several week period, the pilot testing should be conducted during the summer months so that the water can be used for irrigation purposes.

RNVWD has no information on the well pump and motor installed in Well 2. Therefore, additional well and pump field testing can be conducted in conjunction with the pilot testing to acquire information on Well 2 pump hydraulics, motor horsepower requirements, and overall operating efficiency. In addition, the well could be tested for specific capacity and the results compared to the specific capacity measured at the time Well 2 was originally constructed (see **Table 2**).

Engineering Feasibility Study and Conceptual Design

The engineering feasibility study and conceptual design of Well 2 treatment system should be completed following pilot testing. The engineering feasibility study would address the following:

- Summarize pilot testing results and compare the technical feasibility and treatment costs for adsorptive media versus chemical precipitation;
- Determine the optimum treatment unit configurations and conceptual layouts (space requirements);
- Summarize the quantity and quality of residuals generated as determined by pilot testing and costs for residual permitting, transportation, and disposal;
- Evaluate filter backwashing requirements and backwash source-water pros and cons for backwashing the units (compare using RNVWD distribution system water versus designing the filter units to be able to sequentially backwash using filter-unit treated water);
- Define chemical feed requirements and modifications needed to upgrade existing chemical feed and storage facilities.
- Assess system hydraulics (i.e. evaluate the need for Well 2 pump and motor modifications based upon head requirements for well head treatment);
- Define measures needed to prevent RNVWD from being locked into a single system/vendor with no option available to competitively bid future upgrades and media exchanges;

The proposed Well 2 water treatment system will be located at the Well 1 site as shown on **Figure 3**. Fortunately, when Well 1 was originally constructed, provisions were made to add future treatment of Well 2 water at Well 1 site. As **Figure 3** indicates the Well 2 water is currently routed to the Well 1 site

and joins Well 1 just in front of the existing hydro-pneumatic tank. A picture of the Well 1 site (see **Figure 4**) shows many of the salient features included in **Figure 3**.

Conclusions and Recommendations

- 1) Well 2 has arsenic concentrations ranging from about 5 to 21 parts per billion (ppb) and exceed the 10 ppb regulatory standard.
- 2) RNVWD desires to improve water supply reliability by reducing arsenic levels in Well 2 and retained LSCE to assessing possible Well 2 options that could lower arsenic levels:
 5. Option 1- blending Well 2 water with Well 1 to achieve an arsenic level that meets the 10 ppb standard;
 6. Option 2- construction of a new, low arsenic well to replace Well 2;
 7. Option 3- make modifications to the existing Well 2 structure to limit arsenic entry into the well casing;
 8. Option 4- construct groundwater treatment facilities to remove arsenic.
- 3) DDW classifies Well 2 as an emergency standby groundwater source and therefore Well 2 can only be used for short term emergencies of 5 consecutive days or less and less than 15 calendar days a year. Changing Well 2 to “active” status instead of “standby” would improve RNVWD’s system reliability.
- 4) DDW requires RNVWD’s water supply to meet the Maximum Day Demand (MDD). MDD is defined as the largest volume of water delivered to the system in a single day expressed in gallons per day. LSCE assumes that any Well 2 improvement option to reduce arsenic must result in Well 2 being able to meet the MDD demand of 0.494 million gallons (MG) or 350 gpm.
- 5) Option 1- blending Well 2 water with Well 1 to achieve an arsenic level that meets the 10 ppb standard is not feasible because if Well 1 is out-of-service for any reason, Well 2 would not be able to produce water that meets the arsenic MCL of 10 ppb.
- 6) Option 2- construction of a new, low arsenic well to replace Well 2 is technically feasible. Well 1 produces water having arsenic levels about half the 10 ppb MCL. Therefore, this option would involve constructing a new well located as close as possible to Well 1. A new well replacement project is estimated to cost \$1,350,000. Unfortunately, there would still be some risk that the water quality could still exceed the 10 ppb arsenic standard.
- 7) LSCE conducted packer testing which suggests that Option 3 modifications to the existing Well 2 structure to limit arsenic entry into the well casing is technically unfeasible.
- 8) A wide range of technologies has been developed for the removal of arsenic from well water. However, the two most feasible Option 4 treatment processes involve use of adsorptive media or chemical precipitation. Adsorptive treatment units are relatively low-cost and simple to operate; however, competing ions present in Well 2 groundwater will cause the media to be inefficient in terms of adsorption of arsenic. The only way that the adsorptive media process can compete with the chemical precipitation process, in terms of operational cost, is if the volume of Well 2 water is minimized (i.e. treating less volume means the adsorptive media will last longer before being

spent and having to be replaced with new media). Conversations with the RNVWD general manager indicated a reasonable assumption may be to assume that Well 1 could be off-line for a two-month period and therefore Well 2 treatment would be needed for this two month down-time.

- 9) Option 4 (Well 2 treatment) is technically feasible and can more reliably meet the 10 ppb arsenic standard when compared to all options. In addition, the capital cost for Option 4 (\$750,000 to \$950,000) is less than the only other technically feasible option (Option 2 - \$1,350,000). The annual operating cost for Option 4 is more than Option 2 (the new well option); however, the lower operating cost for Option 2 is judged not to be significant enough to off-set the risk of possibly not being able to meet the 10 ppb arsenic standard.
- 10) Option 4 capital costs for adsorptive media treatment (\$750,000), is estimated to be lower than chemical precipitation treatment (\$950,000). The operational costs for an adsorptive media assuming infrequent operation (i.e. Well 2 is used only when Well 1 fails to operate and must be brought off-line) is also less than the coagulation/filtration treatment process because of the need for additional chemical treatment and because of the operational needs associated with more sludge production in the case of chemical precipitation. In addition, the level of operator training and expertise required to operate an adsorptive media system is less than the coagulation/filtration treatment. Both adsorptive media chemical precipitation units will have media filters that must be conditioned and have chemical feed systems that must be operated more-or-less monthly to ensure an ability to effectively remove arsenic when called upon to operate (when Well 1 fails to operate and must be brought off-line). Although well head treatment may be used infrequently, the operating costs for the RNVWD operators to carry out routine operations to ensure the Well 2 wellhead treatment system is available at a moment's notice is expected to be lower for adsorptive media units than for chemical precipitation units. Pilot testing will be used to verify cost assumptions.
- 11) Pilot testing is required to determine the optimum Well 2 water treatment configurations and operating conditions for meeting the drinking water standard for arsenic. The pilot testing will also provide information on the quantity of residuals generated by treatment and whether the residuals are hazardous or nonhazardous.
- 12) An engineering feasibility study and conceptual design would follow the pilot testing that would compare the technical feasibility and treatment costs for adsorptive media versus chemical precipitation, determine the optimum treatment unit configuration, quantity and quality of residuals generated, and costs for residual permitting, transportation, and disposal.
- 13) The proposed water treatment system will be located at the Well 1 site where provisions already exist for adding future treatment of Well 2 water at the Well 1 site.


LIST OF FIGURES


Figure 1: Well 1 & 2 Profiles


Figure 2: Peak Volume for 2 Month Period

Figure 3: Well 1 Layout with Provisions for Future Well 2 Treatment

Figure 4: Picture of Well 1 Layout with Provisions for Future Well 2 Treatment







CAD FILE: G:/Projects/Rural North Vacaville Wtr Dist/15-2-112/RNWD_As-Builts/RNV DWG's past 0004/Figure 3.dwg DATE: 03-13-17 9:18am



LUHDORFF & SCALMANINI
CONSULTING ENGINEERS

Figure 3
Well 1 Layout with Provisions
for Future Well 2 Treatment



APPENDIX A
Water Quality Data



RNVWD Drinking Water Well #1

General Mineral, Physical, and Inorganic Analyses

Common Name	Units	MCL	PHG or (MCLG)	
Sample Dates:				10/3/16
Agress. Ind.	none			12
Alkalinity	mg/L			210
Aluminum	µg/L	1000	600	ND
Antimony	µg/L	6	20	ND
Arsenic	µg/L	10	0.004	6.2
Barium	µg/L	1000	2000	0.076
Beryllium	µg/L	4	1	ND
Bicarbonate	mg/L			210
Cadmium	µg/L	5	0.04	ND
Calcium	mg/L			25
Carbonate	mg/L		9.3	ND
Chloride	mg/L	500		9.1
Chromium	µg/L	50	100	ND
Chrom 6	µg/L	10	0.2	3.9
Color	units	15		ND
Copper	µg/L	1300	300	ND
Cyanide	µg/L	150	150	ND
Fluoride	mg/L	2.0	1	0.35
Hardness	mg/L			120
Hydroxide	mg/L			ND
Iron	µg/L	300		ND
Langelier	none			0.47
Lead	µg/L	15	0.2	ND
Magnesium	mg/L			14
Manganese	µg/L	50		ND
MBAS	mg/L	0.5		ND

Common Name	Units	MCL	PHG or (MCLG)	
Sample Dates:				10/3/16
Mercury	µg/L	2	1.2	ND
Nickel	µg/L	100	12	ND
Nitrate as N	mg/L	10	10	0.69
Nitrite	mg/L	1	1	ND
Odor	TON	3		ND
Orthophosphate	mg/L			0.079
pH	none	6.5-8.5		8.3
Perchlorate	µg/L	6	6	ND
Potassium	mg/L			4.9
Selenium	µg/L	50	30	ND
Silica-dissolved	mg/L			94
Silver	µg/L	100		ND
Sodium	mg/L			67
Spec cond	µmhos/cm	1600		490
Sulfate	mg/L	500		30
TDS	mg/L	1000		360
Thallium	µg/L	2	0.1	ND
Turbidity	NTU	5		0.11
Vanadium	µg/L		50 NL	31
Zinc	µg/L	5000		ND

Italic MCLs are secondary MCLs

NL is a notification level



RNVWD Drinking Water Well #2

General Mineral, Physical, and Inorganic Analyses

Common Name	Units	MCL	PHG or (MCLG)			
Sample Dates:				1/11/17	12/20/16	10/3/16
Agress. Ind.	none			12	12	12
Alkalinity	mg/L			230	240	210
Aluminum	µg/L	1000	600	ND	ND	ND
Antimony	µg/L	6	20	ND	ND	ND
Arsenic	µg/L	10	0.004	6.9	12.0	4.2
Barium	µg/L	1000	2000	0.081	0.056	0.074
Beryllium	µg/L	4	1	ND	ND	ND
Bicarbonate	mg/L			230	240	210
Boron	mg/L			0.14	0.22	NS
Cadmium	µg/L	5	0.04	ND	ND	ND
Calcium	mg/L			25	16	25
Carbonate	mg/L		9.3	ND	ND	ND
Chloride	mg/L	500		9.6	8.3	10
Chromium	µg/L	50	100	ND	ND	ND
Chrom 6	µg/L	10	0.2	3.2	NS	3.2
Color	units	15		ND	NS	ND
Copper	µg/L	1300	300	ND	ND	ND
Cyanide	µg/L	150	150	ND	ND	ND
Fluoride	mg/L	2.0	1	0.28	0.21	0.36
Hardness	mg/L			120	75	120
Hydroxide	mg/L			ND	ND	ND
Iron	mg/L	0.3		0.094	0.097	0.52
Langelier	none			0.31	0.38	0.47
Lead	µg/L	15	0.2	ND	ND	ND
Magnesium	mg/L			15	8.3	14
Manganese	mg/L	0.05		0.021	0.016	0.018
MBAS	mg/L	0.5		ND	ND	ND

Common Name	Units	MCL	PHG or (MCLG)			
Sample Dates:				1/11/17	12/20/16	10/3/16
Mercury	µg/L	2	1.2	ND	ND	ND
Nickel	µg/L	100	12	ND	ND	ND
Nitrate as N	mg/L	10	10	0.065	ND	0.065
Nitrite	mg/L	1	1	ND	ND	ND
Odor	TON	3		0.071	NS	ND
Orthophosphate	mg/L			0.076	0.014	0.076
pH	none	6.5-8.5		8.1	8.0	8.3
Perchlorate	µg/L	6	6	ND	ND	ND
Potassium	mg/L			5.5	4.3	4.9
Selenium	µg/L	50	30	ND	ND	ND
Silica-dissolved	mg/L			92	95	91
Silver	µg/L	100		ND	ND	ND
Sodium	mg/L			72	86	68
Spec cond	µmhos/cm	1600		500	500	500
Sulfate	mg/L	500		34	20	30
TDS	mg/L	1000		380	360	370
Thallium	µg/L	2	0.1	ND	ND	ND
Turbidity	NTU	5		0.44	NS	2.9
Vanadium	µg/L		50 NL	18	16	23
Zinc	mg/L	5.0		ND	ND	ND

Italic MCLs are secondary MCLs

NL is a notification level

NS - not sampled

Certificate of Analysis

Sample ID: A7A1318-01
Sampled By: Dean Miner
Sample Description: well #2

Sample Date - Time: 01/11/17 - 11:30

Matrix: Drinking Water

Sample Type: Grab

BSK Associates Laboratory Fresno
General Chemistry

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Aggressive Index		12				A700945	01/23/17	01/23/17	
Alkalinity as CaCO ₃	SM 2320B	230	3.0	mg/L	1	A700575	01/15/17	01/15/17	
Bicarbonate as CaCO ₃	SM 2320B	230	3.0	mg/L	1	A700575	01/15/17	01/15/17	
Carbonate as CaCO ₃	SM 2320B	ND	3.0	mg/L	1	A700575	01/15/17	01/15/17	
Hydroxide as CaCO ₃	SM 2320B	ND	3.0	mg/L	1	A700575	01/15/17	01/15/17	
Chloride	EPA 300.0	9.6	1.0	mg/L	1	A700625	01/16/17	01/16/17	
Color, Apparent	SM 2120B	ND	5.0	CU	1	A700491	01/13/17 17:08	01/13/17	HT1.1
Cyanide (total)	SM 4500-CN E	ND	0.0050	mg/L	1	A700705	01/18/17	01/19/17	
Conductivity @ 25C	SM 2510B	500	1.0	umhos/cm	1	A700575	01/15/17	01/15/17	
Fluoride	EPA 300.0	0.28	0.10	mg/L	1	A700625	01/16/17	01/16/17	
Langlier Index	SM 2330B	0.31				A700945	01/23/17	01/23/17	
Orthophosphate as PO ₄	SM 4500-P E	0.071	0.030	mg/L	1	A700644	01/17/17 12:34	01/17/17	HT1.1
Perchlorate	EPA 314.0	ND	2.0	ug/L	1	A700833	01/19/17	01/19/17	
pH (1)	SM 4500-H+ B	8.1		pH Units	1	A700575	01/15/17	01/15/17	
pH Temperature in °C		20.5							
Sulfate as SO ₄	EPA 300.0	34	1.0	mg/L	1	A700625	01/16/17	01/16/17	
Total Dissolved Solids	SM 2540C	380	5.0	mg/L	1	A700714	01/18/17	01/23/17	
Turbidity	SM 2130B	0.44	0.10	NTU	1	A700491	01/13/17 17:23	01/13/17	HT1.1

Metals

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Aluminum	EPA 200.7	ND	0.050	mg/L	1	A700672	01/18/17	01/18/17	
Antimony	EPA 200.8	ND	2.0	ug/L	1	A700672	01/18/17	01/24/17	
Arsenic	EPA 200.8	6.9	2.0	ug/L	1	A700672	01/18/17	01/24/17	
Barium	EPA 200.7	0.081	0.050	mg/L	1	A700672	01/18/17	01/18/17	
Beryllium	EPA 200.8	ND	1.0	ug/L	1	A700672	01/18/17	01/24/17	
Boron	EPA 200.7	0.14	0.10	mg/L	1	A700672	01/18/17	01/18/17	
Cadmium	EPA 200.8	ND	1.0	ug/L	1	A700672	01/18/17	01/24/17	
Calcium	EPA 200.7	25	0.10	mg/L	1	A700672	01/18/17	01/18/17	
Chromium	EPA 200.8	ND	10	ug/L	1	A700672	01/18/17	01/24/17	
Copper	EPA 200.8	ND	5.0	ug/L	1	A700672	01/18/17	01/24/17	
Iron	EPA 200.7	0.094	0.030	mg/L	1	A700672	01/18/17	01/18/17	
Lead	EPA 200.8	ND	5.0	ug/L	1	A700672	01/18/17	01/24/17	
Magnesium	EPA 200.7	15	0.10	mg/L	1	A700672	01/18/17	01/18/17	
Manganese	EPA 200.7	0.021	0.010	mg/L	1	A700672	01/18/17	01/18/17	
Mercury	EPA 200.8	ND	0.20	ug/L	1	A700672	01/18/17	01/24/17	
Nickel	EPA 200.8	ND	10	ug/L	1	A700672	01/18/17	01/24/17	
Potassium	EPA 200.7	5.5	2.0	mg/L	1	A700672	01/18/17	01/18/17	
Selenium	EPA 200.8	ND	2.0	ug/L	1	A700672	01/18/17	01/24/17	
Silica (SiO ₂) - Dissolved (1)	EPA 200.7	92	0.20	mg/L	1	A700641	01/17/17	01/18/17	
Silver	EPA 200.8	ND	10	ug/L	1	A700672	01/18/17	01/24/17	
Sodium	EPA 200.7	72	1.0	mg/L	1	A700672	01/18/17	01/18/17	MS1.4
Thallium	EPA 200.8	ND	1.0	ug/L	1	A700672	01/18/17	01/24/17	

Certificate of Analysis
Sample ID: A7A1318-01

Sampled By: Dean Miner

Sample Description: well #2

Sample Date - Time: 01/11/17 - 11:30

Matrix: Drinking Water

Sample Type: Grab

Metals

Analyte	Method	Result	RL	Units	RL MULT	Batch	Prepared	Analyzed	Qual
Hardness as CaCO ₃	SM 2340B	120	0.41	mg/L					
Vanadium	EPA 200.8	18	3.0	ug/L	1	A700672	01/18/17	01/24/17	
Zinc	EPA 200.7	ND	0.050	mg/L	1	A700672	01/18/17	01/18/17	

Certificate of Analysis

Sample ID: A6L2216-01
Sampled By: Dean Miner
Sample Description: Well #2

Sample Date - Time: 12/20/16 - 09:20
Matrix: Drinking Water
Sample Type: Grab

BSK Associates Laboratory Fresno
General Chemistry

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Aggressive Index		12				A617597	12/30/16	12/30/16	
Alkalinity as CaCO ₃	SM 2320B	240	3.0	mg/L	1	A617366	12/26/16	12/26/16	
Bicarbonate as CaCO ₃	SM 2320B	240	3.0	mg/L	1	A617366	12/26/16	12/26/16	
Carbonate as CaCO ₃	SM 2320B	ND	3.0	mg/L	1	A617366	12/26/16	12/26/16	
Hydroxide as CaCO ₃	SM 2320B	ND	3.0	mg/L	1	A617366	12/26/16	12/26/16	
Chloride	EPA 300.0	8.3	1.0	mg/L	1	A617171	12/21/16	12/21/16	
Cyanide (total)	SM 4500-CN E	ND	0.0050	mg/L	1	A617331	12/23/16	12/30/16	
Conductivity @ 25C	SM 2510B	500	1.0	umhos/cm	1	A617366	12/26/16	12/26/16	
Fluoride	EPA 300.0	0.21	0.10	mg/L	1	A617171	12/21/16	12/21/16	
Langelier Index	SM 2330B	0.038				A617597	12/30/16	12/30/16	
MBAS, Calculated as LAS, mol wt 340	SM 5540C	ND	0.050	mg/L	1	A617217	12/21/16 20:20	12/21/16	
Nitrate + Nitrite as N	EPA 300.0	ND	0.23	mg/L	1	A617171	12/21/16 18:52	12/21/16	
Nitrate as N	EPA 300.0	ND	0.23	mg/L	1	A617171	12/21/16 18:52	12/21/16	
Nitrite as N	EPA 300.0	ND	0.050	mg/L	1	A617171	12/21/16 18:52	12/21/16	
Orthophosphate as P	SM 4500-P E	0.014	0.010	mg/L	1	A617229	12/22/16 08:42	12/22/16	
Perchlorate	EPA 314.0	ND	2.0	ug/L	1	A617469	12/28/16	12/28/16	
pH (1)	SM 4500-H+ B	8.0		pH Units	1	A617366	12/26/16	12/26/16	
pH Temperature in °C		22.9							
Sulfate as SO ₄	EPA 300.0	20	1.0	mg/L	1	A617171	12/21/16	12/21/16	
Total Dissolved Solids	SM 2540C	360	5.0	mg/L	1	A617328	12/23/16	12/29/16	

Metals

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Aluminum	EPA 200.7	ND	0.050	mg/L	1	A617273	12/23/16	12/29/16	
Antimony	EPA 200.8	ND	2.0	ug/L	1	A617273	12/23/16	01/04/17	
Arsenic	EPA 200.8	12	2.0	ug/L	1	A617273	12/23/16	01/04/17	
Barium	EPA 200.7	0.056	0.050	mg/L	1	A617273	12/23/16	12/29/16	
Beryllium	EPA 200.8	ND	1.0	ug/L	1	A617273	12/23/16	01/04/17	
Boron	EPA 200.7	0.22	0.10	mg/L	1	A617273	12/23/16	12/29/16	
Cadmium	EPA 200.8	ND	1.0	ug/L	1	A617273	12/23/16	01/04/17	
Calcium	EPA 200.7	16	0.10	mg/L	1	A617273	12/23/16	12/29/16	
Chromium	EPA 200.8	ND	10	ug/L	1	A617273	12/23/16	01/04/17	
Copper	EPA 200.7	ND	0.050	mg/L	1	A617273	12/23/16	12/29/16	
Hardness as CaCO ₃		75	0.41	mg/L					
Iron	EPA 200.7	0.097	0.030	mg/L	1	A617273	12/23/16	12/29/16	
Lead	EPA 200.8	ND	5.0	ug/L	1	A617273	12/23/16	01/04/17	
Magnesium	EPA 200.7	8.3	0.10	mg/L	1	A617273	12/23/16	12/29/16	
Manganese	EPA 200.7	0.016	0.010	mg/L	1	A617273	12/23/16	12/29/16	
Mercury	EPA 200.8	ND	0.20	ug/L	1	A617273	12/23/16	01/04/17	
Nickel	EPA 200.8	ND	10	ug/L	1	A617273	12/23/16	01/04/17	
Potassium	EPA 200.7	4.3	2.0	mg/L	1	A617273	12/23/16	12/29/16	
Selenium	EPA 200.8	ND	2.0	ug/L	1	A617273	12/23/16	01/04/17	
Silica (SiO ₂) - Dissolved (1)	EPA 200.7	95	0.20	mg/L	1	A617550	12/30/16	01/04/17	

**A6L2216****Master -EDT**

RNWWD Arsenic Study Well 2

Certificate of Analysis**Sample ID:** A6L2216-01**Sampled By:** Dean Miner**Sample Description:** Well #2**Sample Date - Time:** 12/20/16 - 09:20**Matrix:** Drinking Water**Sample Type:** Grab**Metals**

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Silver	EPA 200.7	ND	0.010	mg/L	1	A617273	12/23/16	12/30/16	
Sodium	EPA 200.7	86	1.0	mg/L	1	A617273	12/23/16	12/29/16	
Thallium	EPA 200.8	ND	1.0	ug/L	1	A617273	12/23/16	01/04/17	
Vanadium	EPA 200.8	16	3.0	ug/L	1	A617273	12/23/16	01/04/17	
Zinc	EPA 200.7	ND	0.050	mg/L	1	A617273	12/23/16	12/29/16	

Certificate of Analysis

Sample ID: A6J0174-02
Sampled By: Dean Miner
Sample Description: Well #2

Sample Date - Time: 10/03/16 - 09:25

Matrix: Drinking Water

Sample Type: Grab

BSK Associates Fresno
General Chemistry

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Aggressive Index		12				A614103	10/13/16	10/13/16	
Alkalinity as CaCO ₃	SM 2320B	210	3.0	mg/L	1	A613515	10/05/16	10/05/16	
Bicarbonate as CaCO ₃	SM 2320B	210	3.0	mg/L	1	A613515	10/05/16	10/05/16	
Carbonate as CaCO ₃	SM 2320B	ND	3.0	mg/L	1	A613515	10/05/16	10/05/16	
Hydroxide as CaCO ₃	SM 2320B	ND	3.0	mg/L	1	A613515	10/05/16	10/05/16	
Chloride	EPA 300.0	10	1.0	mg/L	1	A613464	10/04/16	10/04/16	
Color, Apparent	SM 2120B	ND	5.0	CU	1	A613409	10/04/16 12:16	10/04/16	
Cyanide (total)	SM 4500-CN E	ND	0.0050	mg/L	1	A613845	10/10/16	10/10/16	
Conductivity @ 25C	SM 2510B	500	1.0	umhos/cm	1	A613515	10/05/16	10/05/16	
Fluoride	EPA 300.0	0.36	0.10	mg/L	1	A613464	10/04/16	10/04/16	
Hexavalent Chromium	EPA 218.7	3.2	0.050	ug/L	1	A613709	10/06/16	10/06/16	
Langelier Index	SM 2330B	0.47				A614103	10/13/16	10/13/16	
MBAS, Calculated as LAS, mol wt 340	SM 5540C	ND	0.050	mg/L	1	A613469	10/04/16 15:13	10/04/16	
Nitrate + Nitrite as N	EPA 300.0	0.65	0.23	mg/L	1	A613464	10/04/16 19:11	10/04/16	
Nitrate as N	EPA 300.0	0.65	0.23	mg/L	1	A613464	10/04/16 19:11	10/04/16	
Nitrite as N	EPA 300.0	ND	0.050	mg/L	1	A613464	10/04/16 19:11	10/04/16	
Orthophosphate as PO ₄	SM 4500-P E	0.076	0.030	mg/L	1	A613481	10/04/16 13:25	10/04/16	
Perchlorate	EPA 314.0	ND	2.0	ug/L	1	A613883	10/11/16	10/11/16	
pH (1)	SM 4500-H+ B	8.3		pH Units	1	A613515	10/05/16	10/05/16	
pH Temperature in °C		22.4							
Sulfate as SO ₄	EPA 300.0	30	1.0	mg/L	1	A613464	10/04/16	10/04/16	
Total Dissolved Solids	SM 2540C	370	5.0	mg/L	1	A613583	10/05/16	10/07/16	
Turbidity	SM 2130B	2.9	0.10	NTU	1	A613409	10/04/16 12:32	10/04/16	

Metals

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Aluminum	EPA 200.7	ND	0.050	mg/L	1	A613770	10/09/16	10/12/16	
Antimony	EPA 200.8	ND	2.0	ug/L	1	A613770	10/09/16	10/14/16	
Arsenic	EPA 200.8	4.2	2.0	ug/L	1	A613770	10/09/16	10/14/16	
Barium	EPA 200.7	0.074	0.050	mg/L	1	A613770	10/09/16	10/12/16	
Beryllium	EPA 200.8	ND	1.0	ug/L	1	A613770	10/09/16	10/14/16	
Cadmium	EPA 200.8	ND	1.0	ug/L	1	A613770	10/09/16	10/14/16	
Calcium	EPA 200.7	25	0.10	mg/L	1	A613770	10/09/16	10/12/16	
Chromium	EPA 200.8	ND	10	ug/L	1	A613770	10/09/16	10/14/16	
Copper	EPA 200.8	ND	5.0	ug/L	1	A613770	10/09/16	10/14/16	
Iron	EPA 200.7	0.52	0.030	mg/L	1	A613770	10/09/16	10/12/16	
Lead	EPA 200.8	ND	5.0	ug/L	1	A613770	10/09/16	10/14/16	
Magnesium	EPA 200.7	14	0.10	mg/L	1	A613770	10/09/16	10/12/16	
Manganese	EPA 200.7	0.018	0.010	mg/L	1	A613770	10/09/16	10/12/16	
Mercury	EPA 200.8	ND	0.20	ug/L	1	A613770	10/09/16	10/14/16	
Nickel	EPA 200.8	ND	10	ug/L	1	A613770	10/09/16	10/14/16	
Potassium	EPA 200.7	4.9	2.0	mg/L	1	A613770	10/09/16	10/12/16	
Selenium	EPA 200.8	ND	2.0	ug/L	1	A613770	10/09/16	10/14/16	

Certificate of Analysis
Sample ID: A6J0174-02

Sampled By: Dean Miner

Sample Description: Well #2

Sample Date - Time: 10/03/16 - 09:25

Matrix: Drinking Water

Sample Type: Grab

Metals

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Silica (SiO ₂) - Dissolved (1)	EPA 200.7	91	0.20	mg/L	1	A614062	10/13/16	10/18/16	
Silver	EPA 200.8	ND	10	ug/L	1	A613770	10/09/16	10/14/16	
Sodium	EPA 200.7	68	1.0	mg/L	1	A613770	10/09/16	10/12/16	
Thallium	EPA 200.8	ND	1.0	ug/L	1	A613770	10/09/16	10/14/16	
Hardness as CaCO ₃	SM 2340B	120	0.41	mg/L					
Vanadium	EPA 200.8	23	3.0	ug/L	1	A613770	10/09/16	10/17/16	
Zinc	EPA 200.7	ND	0.050	mg/L	1	A613770	10/09/16	10/12/16	

Certificate of Analysis

Sample ID: A6J0174-01
Sampled By: Dean Miner
Sample Description: Well #1

Sample Date - Time: 10/03/16 - 09:00
Matrix: Drinking Water
Sample Type: Grab

BSK Associates Fresno General Chemistry

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Aggressive Index		12				A614103	10/13/16	10/13/16	
Alkalinity as CaCO ₃	SM 2320B	210	3.0	mg/L	1	A613515	10/05/16	10/05/16	
Bicarbonate as CaCO ₃	SM 2320B	210	3.0	mg/L	1	A613515	10/05/16	10/05/16	
Carbonate as CaCO ₃	SM 2320B	ND	3.0	mg/L	1	A613515	10/05/16	10/05/16	
Hydroxide as CaCO ₃	SM 2320B	ND	3.0	mg/L	1	A613515	10/05/16	10/05/16	
Chloride	EPA 300.0	9.1	1.0	mg/L	1	A613464	10/04/16	10/04/16	
Color, Apparent	SM 2120B	ND	5.0	CU	1	A613409	10/04/16 12:15	10/04/16	
Cyanide (total)	SM 4500-CN E	ND	0.0050	mg/L	1	A613845	10/10/16	10/10/16	
Conductivity @ 25C	SM 2510B	490	1.0	umhos/cm	1	A613515	10/05/16	10/05/16	
Fluoride	EPA 300.0	0.35	0.10	mg/L	1	A613464	10/04/16	10/04/16	
Hexavalent Chromium	EPA 218.7	3.9	0.050	ug/L	1	A613711	10/07/16	10/07/16	
Langelier Index	SM 2330B	0.47				A614103	10/13/16	10/13/16	
MBAS, Calculated as LAS, mol wt 340	SM 5540C	ND	0.050	mg/L	1	A613469	10/04/16 15:13	10/04/16	
Nitrate + Nitrite as N	EPA 300.0	0.69	0.23	mg/L	1	A613464	10/04/16 19:02	10/04/16	
Nitrate as N	EPA 300.0	0.69	0.23	mg/L	1	A613464	10/04/16 19:02	10/04/16	
Nitrite as N	EPA 300.0	ND	0.050	mg/L	1	A613464	10/04/16 19:02	10/04/16	
Orthophosphate as PO ₄	SM 4500-P E	0.079	0.030	mg/L	1	A613481	10/04/16 13:25	10/04/16	
Perchlorate	EPA 314.0	ND	2.0	ug/L	1	A613883	10/10/16	10/10/16	
pH (1)	SM 4500-H+ B	8.3		pH Units	1	A613515	10/05/16	10/05/16	
pH Temperature in °C		22.4							
Sulfate as SO ₄	EPA 300.0	30	1.0	mg/L	1	A613464	10/04/16	10/04/16	
Total Dissolved Solids	SM 2540C	360	5.0	mg/L	1	A613583	10/05/16	10/07/16	
Turbidity	SM 2130B	0.11	0.10	NTU	1	A613409	10/04/16 12:31	10/04/16	

Metals

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Aluminum	EPA 200.7	ND	0.050	mg/L	1	A613770	10/09/16	10/12/16	MS1.5
Antimony	EPA 200.8	ND	2.0	ug/L	1	A613770	10/09/16	10/14/16	
Arsenic	EPA 200.8	6.2	2.0	ug/L	1	A613770	10/09/16	10/14/16	
Barium	EPA 200.7	0.076	0.050	mg/L	1	A613770	10/09/16	10/12/16	
Beryllium	EPA 200.8	ND	1.0	ug/L	1	A613770	10/09/16	10/14/16	
Cadmium	EPA 200.8	ND	1.0	ug/L	1	A613770	10/09/16	10/14/16	
Calcium	EPA 200.7	25	0.10	mg/L	1	A613770	10/09/16	10/12/16	
Chromium	EPA 200.8	ND	10	ug/L	1	A613770	10/09/16	10/14/16	
Copper	EPA 200.8	ND	5.0	ug/L	1	A613770	10/09/16	10/14/16	
Iron	EPA 200.7	ND	0.030	mg/L	1	A613770	10/09/16	10/12/16	
Lead	EPA 200.8	ND	5.0	ug/L	1	A613770	10/09/16	10/14/16	
Magnesium	EPA 200.7	14	0.10	mg/L	1	A613770	10/09/16	10/12/16	
Manganese	EPA 200.7	ND	0.010	mg/L	1	A613770	10/09/16	10/12/16	
Mercury	EPA 200.8	ND	0.20	ug/L	1	A613770	10/09/16	10/14/16	
Nickel	EPA 200.8	ND	10	ug/L	1	A613770	10/09/16	10/14/16	
Potassium	EPA 200.7	4.9	2.0	mg/L	1	A613770	10/09/16	10/12/16	
Selenium	EPA 200.8	ND	2.0	ug/L	1	A613770	10/09/16	10/14/16	

**A6J0174****Master -EDT**

RNVWD

Certificate of Analysis**Sample ID:** A6J0174-01**Sampled By:** Dean Miner**Sample Description:** Well #1**Sample Date - Time:** 10/03/16 - 09:00**Matrix:** Drinking Water**Sample Type:** Grab**Metals**

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Silica (SiO ₂) - Dissolved (1)	EPA 200.7	94	0.20	mg/L	1	A614062	10/13/16	10/18/16	
Silver	EPA 200.8	ND	10	ug/L	1	A613770	10/09/16	10/14/16	
Sodium	EPA 200.7	67	1.0	mg/L	1	A613770	10/09/16	10/12/16	
Thallium	EPA 200.8	ND	1.0	ug/L	1	A613770	10/09/16	10/14/16	
Hardness as CaCO ₃	SM 2340B	120	0.41	mg/L					
Vanadium	EPA 200.8	31	3.0	ug/L	1	A613770	10/09/16	10/17/16	
Zinc	EPA 200.7	ND	0.050	mg/L	1	A613770	10/09/16	10/12/16	

Certificate of Analysis

Sample ID: A6J0174-02
Sampled By: Dean Miner
Sample Description: Well #2

Sample Date - Time: 10/03/16 - 09:25
Matrix: Drinking Water
Sample Type: Grab

BSK Associates Fresno General Chemistry

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Aggressive Index		12				A614103	10/13/16	10/13/16	
Alkalinity as CaCO ₃	SM 2320B	210	3.0	mg/L	1	A613515	10/05/16	10/05/16	
Bicarbonate as CaCO ₃	SM 2320B	210	3.0	mg/L	1	A613515	10/05/16	10/05/16	
Carbonate as CaCO ₃	SM 2320B	ND	3.0	mg/L	1	A613515	10/05/16	10/05/16	
Hydroxide as CaCO ₃	SM 2320B	ND	3.0	mg/L	1	A613515	10/05/16	10/05/16	
Chloride	EPA 300.0	10	1.0	mg/L	1	A613464	10/04/16	10/04/16	
Color, Apparent	SM 2120B	ND	5.0	CU	1	A613409	10/04/16 12:16	10/04/16	
Cyanide (total)	SM 4500-CN E	ND	0.0050	mg/L	1	A613845	10/10/16	10/10/16	
Conductivity @ 25C	SM 2510B	500	1.0	umhos/cm	1	A613515	10/05/16	10/05/16	
Fluoride	EPA 300.0	0.36	0.10	mg/L	1	A613464	10/04/16	10/04/16	
Hexavalent Chromium	EPA 218.7	3.2	0.050	ug/L	1	A613709	10/06/16	10/06/16	
Langelier Index	SM 2330B	0.47				A614103	10/13/16	10/13/16	
MBAS, Calculated as LAS, mol wt 340	SM 5540C	ND	0.050	mg/L	1	A613469	10/04/16 15:13	10/04/16	
Nitrate + Nitrite as N	EPA 300.0	0.65	0.23	mg/L	1	A613464	10/04/16 19:11	10/04/16	
Nitrate as N	EPA 300.0	0.65	0.23	mg/L	1	A613464	10/04/16 19:11	10/04/16	
Nitrite as N	EPA 300.0	ND	0.050	mg/L	1	A613464	10/04/16 19:11	10/04/16	
Orthophosphate as PO ₄	SM 4500-P E	0.076	0.030	mg/L	1	A613481	10/04/16 13:25	10/04/16	
Perchlorate	EPA 314.0	ND	2.0	ug/L	1	A613883	10/11/16	10/11/16	
pH (1)	SM 4500-H+ B	8.3		pH Units	1	A613515	10/05/16	10/05/16	
pH Temperature in °C		22.4							
Sulfate as SO ₄	EPA 300.0	30	1.0	mg/L	1	A613464	10/04/16	10/04/16	
Total Dissolved Solids	SM 2540C	370	5.0	mg/L	1	A613583	10/05/16	10/07/16	
Turbidity	SM 2130B	2.9	0.10	NTU	1	A613409	10/04/16 12:32	10/04/16	

Metals

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Aluminum	EPA 200.7	ND	0.050	mg/L	1	A613770	10/09/16	10/12/16	
Antimony	EPA 200.8	ND	2.0	ug/L	1	A613770	10/09/16	10/14/16	
Arsenic	EPA 200.8	4.2	2.0	ug/L	1	A613770	10/09/16	10/14/16	
Barium	EPA 200.7	0.074	0.050	mg/L	1	A613770	10/09/16	10/12/16	
Beryllium	EPA 200.8	ND	1.0	ug/L	1	A613770	10/09/16	10/14/16	
Cadmium	EPA 200.8	ND	1.0	ug/L	1	A613770	10/09/16	10/14/16	
Calcium	EPA 200.7	25	0.10	mg/L	1	A613770	10/09/16	10/12/16	
Chromium	EPA 200.8	ND	10	ug/L	1	A613770	10/09/16	10/14/16	
Copper	EPA 200.8	ND	5.0	ug/L	1	A613770	10/09/16	10/14/16	
Iron	EPA 200.7	0.52	0.030	mg/L	1	A613770	10/09/16	10/12/16	
Lead	EPA 200.8	ND	5.0	ug/L	1	A613770	10/09/16	10/14/16	
Magnesium	EPA 200.7	14	0.10	mg/L	1	A613770	10/09/16	10/12/16	
Manganese	EPA 200.7	0.018	0.010	mg/L	1	A613770	10/09/16	10/12/16	
Mercury	EPA 200.8	ND	0.20	ug/L	1	A613770	10/09/16	10/14/16	
Nickel	EPA 200.8	ND	10	ug/L	1	A613770	10/09/16	10/14/16	
Potassium	EPA 200.7	4.9	2.0	mg/L	1	A613770	10/09/16	10/12/16	
Selenium	EPA 200.8	ND	2.0	ug/L	1	A613770	10/09/16	10/14/16	

**A6J0174****Master -EDT**

RNVWD

Certificate of Analysis**Sample ID:** A6J0174-02**Sampled By:** Dean Miner**Sample Description:** Well #2**Sample Date - Time:** 10/03/16 - 09:25**Matrix:** Drinking Water**Sample Type:** Grab**Metals**

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Silica (SiO ₂) - Dissolved (1)	EPA 200.7	91	0.20	mg/L	1	A614062	10/13/16	10/18/16	
Silver	EPA 200.8	ND	10	ug/L	1	A613770	10/09/16	10/14/16	
Sodium	EPA 200.7	68	1.0	mg/L	1	A613770	10/09/16	10/12/16	
Thallium	EPA 200.8	ND	1.0	ug/L	1	A613770	10/09/16	10/14/16	
Hardness as CaCO ₃	SM 2340B	120	0.41	mg/L					
Vanadium	EPA 200.8	23	3.0	ug/L	1	A613770	10/09/16	10/17/16	
Zinc	EPA 200.7	ND	0.050	mg/L	1	A613770	10/09/16	10/12/16	

Informational Water Quality Report

Watercheck 1 & 2

**Client:**

Rural North VV Water
Well 002
Vacaville, CA 95688

Ordered By:

Environmental Aqua
896 Aldridge Rd
Suite D
Vacaville, CA 95688
ATTN: Bud Johnson

Sample Number: 845352

Location: Wellhead

Type of Water: Well Water

Collection Date and Time: 5/21/2014 09:10

Received Date and Time: 5/23/2014 10:15

Date Completed: 6/4/2014

Definition and Legend

This informational water quality report compares the actual test result to national standards as defined in the EPA's Primary and Secondary Drinking Water Regulations.

Primary Standards: Are expressed as the maximum contaminant level (MCL) which is the highest level of contaminant that is allowed in drinking water. MCLs are enforceable standards.

Secondary standards: Are non-enforceable guidelines regulating contaminants that may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water. Individual states may choose to adopt them as enforceable standards.

Action levels: Are defined in treatment techniques which are required processes intended to reduce the level of a contaminant in drinking water.

mg/L (ppm): Unless otherwise indicated, results and standards are expressed as an amount in milligrams per liter or parts per million.

Minimum Detection Level (MDL): The lowest level that the laboratory can detect a contaminant.

ND: The contaminant was not detected above the minimum detection level.

NA: The contaminant was not analyzed.

✓ The contaminant was not detected in the sample above the minimum detection level.







● The contaminant was detected at or above the minimum detection level, but not above the referenced standard.

▲ The contaminant was detected above the standard, which is not an EPA enforceable MCL.

✚ The contaminant was detected above the EPA enforceable MCL.

✖ These results may be invalid.

Status	Contaminant	Results	Units	National Standards		Min. Detection Level
Inorganic Analytes - Metals						
✓	Aluminum	ND	mg/L	0.2	EPA Secondary	0.1
✗	Arsenic	0.014	mg/L	0.010	EPA Primary	0.005
✓	Barium	ND	mg/L	2	EPA Primary	0.30
✓	Cadmium	ND	mg/L	0.005	EPA Primary	0.002
●	Calcium	18.0	mg/L	--		2.0
✓	Chromium	ND	mg/L	0.1	EPA Primary	0.010
✓	Copper	ND	mg/L	1.3	EPA Action Level	0.004
●	Iron	0.053	mg/L	0.3	EPA Secondary	0.020
✓	Lead	ND	mg/L	0.015	EPA Action Level	0.002
●	Magnesium	8.88	mg/L	--		0.10
●	Manganese	0.006	mg/L	0.05	EPA Secondary	0.004
✓	Mercury	ND	mg/L	0.002	EPA Primary	0.001
✓	Nickel	ND	mg/L	--		0.020
●	Potassium	5.0	mg/L	--		1.0
✓	Selenium	ND	mg/L	0.05	EPA Primary	0.020
●	Silica	81.1	mg/L	--		0.1
✓	Silver	ND	mg/L	0.100	EPA Secondary	0.002
●	Sodium	81	mg/L	--		1
●	Uranium	0.004	mg/L	0.030	EPA Primary	0.001
●	Vanadium	0.018	mg/L	--		0.015
✓	Zinc	ND	mg/L	5	EPA Secondary	0.004
Physical Factors						
●	Alkalinity (Total as CaCO3)	230	mg/L	--		20
●	Hardness	81	mg/L	100	NTL Internal	10
✓	pH	7.6	pH Units	6.5 to 8.5	EPA Secondary	
●	Total Dissolved Solids	360	mg/L	500	EPA Secondary	20
●	Turbidity	0.3	NTU	1.0	EPA Action Level	0.1

Status	Contaminant	Results	Units	National Standards		Min. Detection Level
Inorganic Analytes - Other						
	Chloride	7.4	mg/L	250	EPA Secondary	5.0
	Fluoride	ND	mg/L	4.0	EPA Primary	0.5
	Nitrate as N	ND	mg/L	10	EPA Primary	0.5
	Nitrite as N	ND	mg/L	1	EPA Primary	0.5
	Ortho Phosphate	ND	mg/L	--		2.0
	Sulfate	22.0	mg/L	250	EPA Secondary	5.0

We certify that the analyses performed for this report are accurate, and that the laboratory tests were conducted by methods approved by the U.S. Environmental Protection Agency or variations of these EPA methods.

These test results are intended to be used for informational purposes only and may not be used for regulatory compliance.